

WDFW Reply to Ecology Comment on Point Whitney Project

From: Peoples, Marty D (DFW)
Sent: Friday, May 31, 2013 10:17 AM
To: Mendoza, Sonia (ECY); Zeigler, Robert C (DFW)
Cc: Gourley, Chris L (DFW); Mercuri, Joyce (ECY); Cornett, Deborah (ECY)
Subject: RE: ECY 13-2421 - Point Whitney Tide Gate Culvert Replacement project - Comments

Sonia, thank-you for your comments concerning the SEPA Checklist submitted by Chris Gourley (WDFW Biologist) for the Point Whitney Project. WDFW will comply with toxic cleanup requirements as specified in your letter. WDFW will have inspectors onsite who will immediately notify Ecology at the provided contact number if any evidence of contaminated soils or groundwater is detected at any point in this construction process.

Erosion control measures will be installed prior to clearing , grading, or construction and will be monitored through-out the construction process to ensure proper functioning. Disposal of construction debris will made at an approved landfill site in an upland location. There will be no opportunity for disposed construction debris to enter waters of the state. WDFW does not anticipate any issues concerning debris disposal but will call the contact person you provided should an issue arise. Thank-you again for your comments and for providing the appropriate contact information,

Marty Peoples
Fish and Wildlife Biologist
WDFW Engineering
(360) 902-8426
Marty.Peoples@dfw.wa.gov

From: Mendoza, Sonia (ECY)
Sent: Friday, May 31, 2013 8:06 AM
To: SEPADesk2 (DFW)
Cc: Mercuri, Joyce (ECY); Cornett, Deborah (ECY); Gourley, Chris L (DFW)
Subject: ECY 13-2421 - Point Whitney Tide Gate Culvert Replacement project - Comments
Importance: High

Mr. Zeigler,
Attached are Ecology's comments for the Point Whitney Tide Gate Culvert Replacement project (Ecology SEPA No. 13-2421). Comments are due today 5/31/13.

Attached is the original final copy.

Please reply to this message for confirmation. Thank you.

Sonia Mendoza 🌸

Department of Ecology-SWRO

SEPA Coordinator

P:360-407-6313 & F:360-407-6305

sonia.mendoza@ecy.wa.gov

Please consider the environment before printing this e-mail